




County of San Bernardino • Department of Public Health
Division of Environmental Health Services

COMMUNITY ENVIRONMENTAL HEALTH PROGRAM
RETAIL FOOD PLAN CHECK - OFFICIAL PLAN REVIEW REPORT

www.sbcounty.gov/dph/dehs

(800) 442-2283

FACILITY NAME NAPACABS		DATE 8/26/2013	SIGNATURE 	
LOCATION 14702 CENTRAL AV, CHINO, CA			REINSPECTION DATE Not Specified	PERMIT EXPIRATION
MAILING ADDRESS 2574 WANDERING RIDGE CHINO HILLS, CA			REHS Diana Almond	
FA # Not Specified	PR # Not Specified	SR # SR0060566	CO # Not Specified	PE 1755
TIME IN 1:15 PM	TIME OUT 1:57 PM	CONTACT Not Captured		PROGRAM IDENTIFIER: None SERVICE: 045 - Plan Check- Billable Inspection Services RESULT: 05 - Corrective Action / Follow up Required ACTION: 03 - Reinspection Required

RETAIL FOOD PLAN CHECK - PLAN CHECK RETAIL FOOD CONSULTATION

17K998 Consultation Inspection

Compliance Date: Not Specified

Not In Compliance

Violation Reference - HSC

Inspector Comments: A charged consultation was conducted today regarding unpermitted wine store.

Wine store is selling prepackaged wine bottles, beer and some hard liquor. Wine and liquor are sold on site as well as on line. (individual sells) During weekend, store samples wine for customers.

Facility uses plastic cups for sampling wine. A Food handling permit-prepackaged food only, will be issued today PE 1619 with the following conditions:

1. Within 30 days provide a four-foot-high wainscot of a durable impervious material on all restroom walls (fiberglass reinforced polyester paneling (FRP), ceramic tile, or stainless steel).
2. Facility shall serve wine for the purpose of wine tasting only, using plastic cups. Since facility is not equipped with three compartment sink, no open food (snacks, soda, coffee) or glass cups shall be allowed without additional plan submittal.
3. Observed existing restroom with out slim foot coving. Flooring (ceramic tile) and base coving are in good condition at the moment. Once base coving is damaged it shall be replaced with approved coving, at least four (4) inches, in a seamless manner, forming a 3/8 inch minimum radius cove as an integral unit

Violation Description: A consultation inspection was conducted on this date.

Overall Inspection Comments

Collected Health Permit application along with Health Permit fee \$564, a receipt will be mailed to operator within 10 business days.

Re inspection required within 30 days to verify restroom compliance.

Photo Attachments:

No Photo Attachments